

Cicagna, 01 Oct 2021

To Whom it may Concern

Here with we confirm that the Unplasticized Polyvinyl Chloride (PVC-U) fittings for piping systems for water supply manufactured by Polypipe Italia are certified by Kiwa Italia S.p.A. and are in conformity with the indicated standard and the requirements.

As required by the UNI EN ISO 1452-3:2010, EN BS 1452-3:2010 and ISO 9001:2015 all batches of POLYPIPE ITALIA s.r.l. are controlled by the Quality System and are subjected to following physical testing required: EN 1452-3 (8.1):

- ✓ Resistance to internal pressure water in water 4,2 x PN at 20°C (1h) in accordance to ISO 12092;
- ✓ Resistance to internal pressure water in water 3,2 x PN at 20°C (1000h) in accordance to ISO 12092;
- ✓ Crushing Test in accordance to EN 802;
- ✓ Vicat softening temperature (VST) in accordance to EN 727;
- ✓ Effect of heating 150°C/60 min in accordance to EN763

In accordance to above Quality System, for marked fittings, we obtained certification from Kiwa UNI, Kitemark, Kiwa, Wras, NF, DVGW and Bureau Veritas.

Yours Faithfully

Roberto Dagnino
Quality Manager

